

# Smoke Ventilation Kit

DoP Ref:  
**K08/12101/13****EN 12101-10**Year of affixation:  
**10****1. Product Type:**

Keylite Budget Roof Window

**2. Unique Identification Code(s):**RZN 4503-T, RZN 43xx-E, RZN 4402-K V2, RZN 4404-K V2,  
RZN 4402-KS V2, RZN 4404-KSV2, RZN 4404-M, RZN 4408-M, RZN  
4408-K, RZN 4416-M, RZN 4404-MS, RZN 4408-MS, RZN 4408-KS**3. Manufacturer:**KEYLITE ROOF WINDOWS  
Derryloran Industrial Est.  
Sandholes Road, Cookstown  
Co. Tyrone BT80 9LU**4. System of System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V of the CPR:**

System 1

**5. Harmonised Standard:**

EN 12101-10

**6. Notified Body:**

VdS Schadenverhütung GmbH - No. 786

**7. Declared Performance:**

Essential Characteristic	Performance	Harmonised Technical Specification
Operation reliability	Pass	EN 12101-10, 2005;
Performance parametes under fire conditions	Class A	
Environmental	Class 1	
Response class	$t \leq 1,5 \text{ sec}$	

# Smoke Ventilation Kit

DoP Ref:  
**K08/12101/13**

**EN 12101-10**

Year of affixation:  
**10**

**8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.**

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

**Date:**

01.08.2013

**Signed:**



**Andy Neal**

(Operations Director)